B5

## FORM –D

Form of Licence under Sub- section (i) of section 6 of the Madras Public Building (Licencing) Act 1965 Tamil Nadu Act 13 of 1965 referred to in Rule 6 of the TamilNadu Buildings (Licencing) Rules 1966.

## BUILDING LICENCE

**Licence No. 56 /2022**

Fees Rs.1000 /-
SBI. Tirupattur.

Remitted in Chalan No :20220506003057
Date: 06.05.2022

**Registration No.K.Dis. B4.2981/2022 Dated : .05.2022**

Lincence is hereby granted to the **correspondent, Don Bosco School of Excellence, Semmozhi Nagar, Vaniyambadi road, Pachal Village, Tirupattur Taluk & District** for the purpose and in respect of the building satisfied in the Statements below and subject to the conditions and for the period mentioned here under.

1. The Period of Validity of the Licence will be from **01.06.2022 to 31.05.2025** (inclusive)
2. This is issued for the building located in **S.F.No. 98pt Semmozhi Nagar, Vaniyambadi road, Pachal Village, Tirupattur Taluk & District**
3. The building should be used as School purpose and not for other purpose.
4. Application for the request of licence Renewal for further period of three years should be made 3 months in advance before the period of Valid date.
5. No additions or alterations should be made before the expiry of the period of licence.
6. If any repairs are to be carried out, care should be taken repairs do not affect the dimension of the building.

**TAHSILDAR,**
TIRUPATTUR

### STATEMENT TO ACCOMPANY THE LICENCE

| *Location of the Building Door No, Street No. and Name of the Place* | *Purpose for which the Building is Licenced to be use as a public building* | *No.of Persons to be accommodated Building* |
|---|---|---|
| 1 | 2 | 3 |
| **S.F.No. 98pt Semmozhi Nagar, Vaniyambadi road, Pachal Village, Tirupattur Taluk, & District** | **School purpose (CBSE School)** | 2062 |

**TAHSILDAR,**
TIRUPATTUR

To

**The correspondent, Don Bosco School of Excellence,**
Semmozhi Nagar, Vaniyambadi road, Pachal Village,
Tirupattur Taluk & District

CORRESPONDENT
Don Bosco School of Excellence
Tirupattur - 635601
Tirupathur District.

PRINCIPAL
Don Bosco School of Excellence
Tirupattur - 635601
Tirupathur District.

Ref: Thirupattur/04/2025 Date: 07.04.2025

**THE TAMIL NADU PUBLIC BUILDINGS (LICENSING) RULES, 1966**
**THE SCHEDULE - FORM - A**

*[Form of application under sub-section (1) / sub-section (2) of section 4 of the Tamil Nadu Public Buildings (Licensing) Act, 1965 (Tamil Nadu Act XIII of 1965) referred to in rules 3 of the Tamil Nadu Public Buildings (Licensing) Rules, 1966]*

From *Name of the owner and address*
CORRESPONDENT
Don Bosco School of Excellence
Tirupattur - 635601
Tirupathur District.

To *The Competent Authority*

Sir

1. I intend / to use the building / to continue to use the existing building / to use the existing building not at present used as a public building / which is situated in the site or plot of land Town or Revenue Survey No S.F.No.98 (Part) Vaniyambadi Road,Semmozhi Nagar Street or Road in the ward of division - /village Pachal Village & Panchayat / Taluk Tirupattur Taluk / District Tirupattur District – 635 601. and specified in the Statement enclosed, as a public building for a period of Three years from 01/06/2025 to 31/05/2028

2. The year of construction and the present approximate cost of construction and the purpose for which it is to be used or is being used as Public building are also furnished in the statement accompanying this application.

3. I enclose a challan for Rs .....

4. I also enclose a certificate of structural soundness in the prescribed form furnished by the Engineer Thiru Er. D.Govindan Registration No A6/5460/2018 (One A) Class of Vellore District,

Dated on ..07.04.2025

Signature of the Owner of the Building
CORRESPONDENT
Don Bosco School of Excellence
Tirupattur - 635601
Tirupathur District.

Enclosures: (1) Statement

(2) Chalan for Rs ..... towards the application fee

*Explanation:- Separate application shall be made in respect of each building*

## STATEMENT ACCOMPANYING FORM A

| | | | |
|---|---|---|---|
| 1 | Door Number of Building: | | Door No.44 |
| 2 | Location:<br><br>Name of Place:<br>Corporation/ Municipality/ Panchayat Panchayat Union/Township/ Cantonment | | **DON BOSCO SCHOOL OF EXCELLENCE**<br>S.F.No.98 (Part),<br>Vaniyambadi Road,Semmozhi Nagar,<br>Pachal Village & Panchayat,<br>Tirupattur Taluk,<br>Tirupattur District – 635 601. |
| 3 | Year of Construction | | **REFER ANNEXURE - I** |
| 4 | Approximate cost of construction as per current rates: | | **REFER ANNEXURE - I** |
| 5 | Purpose for which the building is being used or proposed to be used | | EDUCATIONAL INSTITUTION |
| 6 | Purpose for which the building has hither to been used | | To Run **DON BOSCO SCHOOL OF EXCELLENCE** |
| 7 | Latitude and Longitude Coordinates of the site | | Latitude : 12.519584<br>Longitude : 78.568526 |
| 8 | Details of Construction of the Building (particulars of the foundation soil, specifications of the various parts under | | RCC Framed Structure |
| | (1) | Foundation | R.C.C Columns in c.m |
| | (2) | Basement | R.C.C Plinth Beam in c.m |
| | (3) | Superstructure | R.C.C Columns, Brick Work in C.m & Cement Plastered |
| | (4) | Floor and Roof are to be given | **FLOORING** : Tiles & Cement Flooring<br>**ROOFING** : R.C.C Roof Slab |
| 9 | Period for which licence is required | | **01/06/2025 to 31/05/2028** |
| 10 | Number of persons to be accommodated | | **2062** Persons **(Two Thousand and Sixty Two Persons Only)** |

Dated: **07.04.2025**

Certified that no addition or alteration has been made to the existing building or portion of a building for which this application has been made. I undertake to obtain a fresh license in case any addition or alteration is made to the existing building or portion of building. I also undertake to obtain a fresh license if the purpose for which the license was granted for the use of the building or a portion of the building originally is changed or altered subsequently.

07/04/2025

**Signature of the Engineer**

**Signature of the owner of the building**

CORRESPONDENT
Don Bosco School of Excellence
Tirupattur - 635601
Tirupathur District.

D. GOVINDAN, M.E.,M.Sc.(REV).,M.I.E.,F.I.V
Regd Engineer Grade I, Regd Quality Auditor,
Regd Structural Engineer Grade I,
Chartered Engineer & Regd Bank Panel Valuer,
Collerctorate Panel Engineer, Wealth Tax Valuer,
1168-B, Thendral Nagar Main Road, Vengikkal,
Tiruvannamalai - 606 604. Ph 04175-233275
Mob. No : 9443228723, 7708021591

# FORM – B

*(Form of certificate of structural Soundness under sub-section (4) of section 4 of the Tamil Nadu Public Buildings (Licensing) Act, 1965*

*(Tamil Nadu Act XIII of 1965) referred in rule 4 of the Tamil Nadu Public Buildings (Licensing) Rules, 1966)*

I certify that I have inspected the building mentioned in the statement and furnish below its salient technical features:

| | | | |
|---|---|---|---|
| (1) | Foundation:- | | RCC Framed Structure |
| | (i) | Depth below Ground level | 6' Below Ground Level |
| | (ii) | Nature of soil met with at foundation level | Hard Gravel |
| | (iii) | Pressure at foundation | 2.80 Kg/Sq cm |
| | (iv) | Probable safe bearing capacity of the strata met with at foundation | 5.50 Kg/Sq cm |
| (2) | Superstructure | | |
| | (i) | Maximum stress in the most critical section of masonry and concrete | RCC Framed Structure, RCC Columns, Beams and Brick Masonary Wall |
| | (ii) | Nature of masonry and concrete, and its safe permissible stress. | RCC Roof Slab |

The structural soundness of the building has been verified by me with reference to I.S.I loading standards **875** (Latest version) and other relevant Indian Standards Code of Practice and I declare that the building is structurally sound to be used as a public building for the purpose noted in the statement. A license may be granted for the period from the **01/06/2025** to **31/05/2028** both days inclusive

Date: **07.04.2025**

**Signature of the Engineer** : 07/04/2025
Registration No. : A6/5460/2018
Class : 1A (One A)
Address : 1168-B,Thendral Nagar,
Vengikkal Post, Tiruvannamalai
Taluk & District– 606 604.

**D. GOVINDAN,** M.E.,M.Sc.(REV).,M.I.E.,F.I.V
Regd Engineer Grade I, Regd Quality Auditor,
Regd Structural Engineer Grade I,
Chartered Engineer & Regd Bank Panel Valuer,
Collerctorate Panel Engineer, Wealth Tax Valuer
1168-B, Thendral Nagar Main Road, Vengikkal,
Tiruvannamalai - 606 604. Ph 04175-233275
Mob. No : 9443228723, 7708021591

## STATEMENT TO ACCOMPANY

## THE CERTIFICATE OF STRUCTURAL SOUNDNESS

| Location of the building - Door Number, Street and name of the place | Age of Building | The value of the Building at the current rates | Number of storeys | Short description of structures– Steel – RCC framed of load bearing masonry | Purpose for which the building is certified for use | The period for which the building will be structurally sound | Number of persons to be accommodated | Remarks |
|---|---|---|---|---|---|---|---|---|
| (1) | (2) | (3) | (4) | (5) | (6) | (7) | (8) | (9) |
| **DON BOSCO SCHOOL OF EXCELLENCE** S.F.No.98 (Part), Vaniyambadi Road, Semmozhi Nagar, Pachal Village & Panchayat, Tirupattur Taluk, Tirupattur District – 635 601. | **REFER ANNEXURE - I** | **REFER ANNEXURE - I** | Ground Floor, First Floor & Second Floor Only | RCC Framed Structure | To Run **DON BOSCO SCHOOL OF EXCELLENCE** | **(01/06/ 2025) to (31/05/ 2028)** | **2062** Persons **(Two Thousand and Sixty Two Persons Only)** | - |

D. Govindan 07/04/2025

**Date:07.04.2025.**

**Signature of the Engineer:**

Class : 1A (One A)
Registration No : A6/5460/2018
Address : 1168-B, Thendral Nagar,
Vengikkal Post,
Tiruvannamalai-606 604
Cell No: 94432 28723
Office: 76048 01968

**D. GOVINDAN,** M.E.,M.Sc.(REV).,M.I.E.,F.I.V
Regd Engineer Grade I, Regd Quality Auditor,
Regd Structural Engineer Grade I,
Chartered Engineer & Regd Bank Panel Valuer,
Collerctorate Panel Engineer, Wealth Tax Valuer
1168-B, Thendral Nagar Main Road, Vengikkal,
Tiruvannamalai - 606 604. Ph 04175-233275
Mob. No : 9443228723, 7708021591

# FORM – C

*(Form of certificate of structural Soundness under sub-section (4) of section 4 of the Tamil Nadu Public Buildings (Licensing) Act, 1965*

*(Tamil Nadu Act XIII of 1965) referred to in rule 4 of the Tamil Nadu Public Buildings (Licensing) Rules, 1966)*

I certify that I have inspected the building mentioned in the statement and furnish below its salient technical features:

| | | | |
|---|---|---|---|
| (1) | Foundation:- | | RCC Framed Structure |
| | (i) | Depth below Ground level | 6' Below Ground Level |
| | (ii) | Nature of soil met with at foundation level | Hard Gravel |
| | (iii) | Pressure at foundation | 2.80 Kg/Sq cm |
| | (iv) | Probable safe bearing capacity of the strata met with at foundation | 5.50 Kg/Sq cm |
| (2) | Superstructure | | |
| | (i) | Maximum stress in the most critical section of masonry and concrete | RCC Framed Structure, RCC Columns, Beams and Brick Masonary Wall |
| | (ii) | Nature of masonry, concrete, and its safe permissible stress. | RCC Roof Slab |

The structural soundness of the building has been verified by me with reference to I.S.I loading standards **875** (Latest version) and other relevant Indian Standards Code of Practice and I declare that the building is structurally sound to be used as a public building for the purpose noted in the statement. A license may be granted for the Period from the **01/06/2025** to **31/05/2028** both days inclusive.

07/04/2025

Date: **07.04.2025.**

**Signature of the Engineer, Designation**
Class : 1A (One A)
Registration No : A6/5460/2018

**D. GOVINDAN**, M.E.,M.Sc.(REV).,M.I.E.,F.I.V
Regd Engineer Grade I, Regd Quality Auditor,
Regd Structural Engineer Grade I,
Chartered Engineer & Regd Bank Panel Valuer,
Collerctorate Panel Engineer, Wealth Tax Valuer
1168-B, Thendral Nagar Main Road, Vengikkal,
Tiruvannamalai - 606 604. Ph 04175-233275
Mob. No : 9443228723, 7708021591

## STATEMENT TO ACCOMPANY
## THE CERTIFICATE OF STRUCTURAL SOUNDNESS

### ANNEXURE – I

| Sl. No | Buildings | Year of construction | Area of Building in Sq.ft. | Approx. cost in lakhs. | Age of the Building |
|---|---|---|---|---|---|
| 1. | **MAIN BUILDING** | | | | |
| | Ground Floor : RCC Roof | 2016 | 26,743.84 | 355.68 | 08 Years Old |
| | First Floor : RCC Roof | 2016 | 26,743.84 | 330.27 | 08 Years Old |
| | Second Floor : RCC Roof | 2016 | 25,835.34 | 317.15 | 08 Years Old |
| | GI Sheet Roof | 2016 | 908.50 | 6.03 | 08 Years Old |
| 2. | **KG BLOCK** | | | | |
| | Ground Floor | 2021 | 9,490.43 | 144.24 | 03 Years Old |
| | First Floor | 2021 | 9,490.43 | 135.23 | 03 Years Old |

D. Govt 07/04/2025

**Date: 07.04.2025.**

**Signature of the Engineer:**

Class : 1A (One A)
Registration No : A6/5460/2018
Address : 1168-B, Thendral Nagar,
Vengikkal Post,
Tiruvannamalai-606 604
Cell No: 94432 28723
Office: 76048 01968

**D. GOVINDAN,** M.E.,M.Sc.(REV).,M.I.E.,F.I.V
Regd Engineer Grade I, Regd Quality Auditor,
Regd Structural Engineer Grade I,
Chartered Engineer & Regd Bank Panel Valuer,
Collerctorate Panel Engineer, Wealth Tax Valuer
1168-B, Thendral Nagar Main Road, Vengikkal,
Tiruvannamalai - 606 604. Ph 04175-233275
Mob. No : 9443228723, 7708021591

## STATEMENT TO ACCOMPANY
## THE CERTIFICATE OF STRUCTURAL SOUNDNESS

### ANNEXURE – I

| Sl. No | NAME OF THE BUILDING | NUMBER OF | | LIBRARY/ MULTI PURPOSE HALL | OFFICE/ PRINCIPAL ROOM | STAFF ROOM/ STORE ROOM |
|---|---|---|---|---|---|---|
| | | CLASS ROOMS | LAB | | | |
| 1. | **MAIN BUILDING** | | | | | |
| | Ground Floor : RCC Roof | 12 | 01 | - | 03 | 05 |
| | First Floor : RCC Roof | 12 | 02 | 01 | 01 | 04 |
| | Second Floor | 09 | 04 | 03 | - | 02 |
| 2. | **KG BLOCK** | | | | | |
| | Ground Floor | 10 | - | - | - | - |
| | First Floor | 10 | - | - | - | - |
| | **Total** | **53** | **07** | **04** | **04** | **11** |

D. Govindan, 07/04/2025

**Date: 07.04.2025.**

**Signature of the Engineer:**


Class : 1A (One A)
Registration No : A6/5460/2018
Address : 1168-B, Thendral Nagar,
Vengikkal Post,
Tiruvannamalai-606 604
Cell No: 94432 28723
Office: 76048 01968

**D. GOVINDAN**, M.E.,M.Sc.(REV).,M.I.E.,F.I.V
Regd Engineer Grade I, Regd Quality Auditor,
Regd Structural Engineer Grade I,
Chartered Engineer & Regd Bank Panel Valuer,
Collerctorate Panel Engineer, Wealth Tax Valuer
1168-B, Thendral Nagar Main Road, Vengikkal,
Tiruvannamalai - 606 604. Ph 04175-233275
Mob. No : 9443228723, 7708021591

## FORM – E

*(Form of report to be made to the Competent authority by inspecting authorities or officers appointed under other Acts under section 28 of the Tamil Nadu Public Buildings (Licensing) Act, 1965 (Tamil Nadu Act XIII of 1965) (Tamil Nadu Act XIII of 1965) referred to in rule 7 of the Tamil Nadu Public Buildings (Licensing) Rules, 1966)*

| | | | |
|---|---|---|---|
| 1 | Name and designation of inspecting authority or officer appointed or having jurisdiction under any other Act or law | : | **Er.D.Govindan,B.E.,M.E.,M.Sc., M.I.E.,F.I.V.,**<br>Collectorate Panel Engineer (A6/5460/2018) Class :1A (One A) Of Vellore District<br>Chartered Civil Engineer (M/131928-5)<br>Govt. Approved Valuer (S.L:823/Category-I/2013-2014) |
| 2 | Location of the building inspected (Door number, Street number, Name of place i.e., Municipal Corporation / Municipality / Panchayat or Panchayat Union / Township / Cantonment) | | **DON BOSCO SCHOOL OF EXCELLENCE**<br>S.F.No.98 (Part),<br>Vaniyambadi Road,Semmozhi Nagar,<br>Pachal Village & Panchayat,<br>Tirupattur Taluk,<br>Tirupattur District – 635 601. |
| 3 | Date of inspection | : | 05.04.2025 |
| 4 | Purpose for which the building is used. | : | Educational Institution |
| 5 | Purpose for which the building has hither to been used | : | To Run **DON BOSCO SCHOOL OF EXCELLENCE** |
| 6 | The period for which the building will be structurally sound | : | **01/06/2025 to 31/05/2028** |
| 7 | Number of persons to be accommodated | : | **2062** Persons **(Two Thousand and Sixty Two Persons Only)** |
| 8 | Nature of defects noticed | : | - |
| 9 | Suggestion for rectifying defects | : | - |
| 10 | If in a dangerous condition, immediate steps recommended to be taken | : | - |

07/04/2025

Signature of inspecting authority

Or officer appointed or having jurisdiction

**D. GOVINDAN, M.E.,M.Sc.(REV).,M.I.E.,F.I.V**
Regd Engineer Grade I, Regd Quality Auditor,
Regd Structural Engineer Grade I,
Chartered Engineer & Regd Bank Panel Valuer,
Collierctorate Panel Engineer, Wealth Tax Valuer
1168-B, Thendral Nagar Main Road, Vengikkal,
Tiruvannamalai - 606 604. Ph 04175-233275
Mob. No : 9443228723, 7708021591

Off: 76048 01968 Mobile: 94432 28723

Er.D.GOVINDAN, B.E., M.E.,(Struct),M.Sc.,(REV), M.I.E., F.I.V.,
1168-B, Thendral Nagar Main Road,
Vengikkal, Tiruvannamalai-606 604.
E-Mail – erdgovindan@gmail.Com

- Collectorate Panel Engineer (A6/5460/2018)
- Chartered Civil Engineer (M/131928-5)
- Income & Wealth tax Valuer (SL.No:823/Category-I/2013-2014)
- Bank Panel Valuer

## STRUCTURAL SOUNDNESS CERTIFICATE RELATING TO SCHOOL

Date: 07.04.2025

### DECLARATION

I, **D. GOVINDAN, B.E., M.E., M.Sc., M.I.E., F.I.V.,** Son of Thiru. R.Dhandapani residing at No. 1168 B, Thendral Nagar Main Road, Vengikkal Post, Tiruvannamalai Taluk and District, do hereby declare that I possess the qualification and experience specified in the structural soundness of the building covered by the certificate.

I am an **APPROVED & REGISTERED ENGINEER by the Collector of VELLORE DISTRICT,** under "Tamil Nadu Public Building (Licensing) Act & Rules 1966", to issue the structural stability certificates to public like the "School" under reference.

07/04/2025

**SIGNATURE OF THE ENGINEER**

D. GOVINDAN, M.E.,M.Sc.(REV).,M.I.E.,F.I.V
Regd Engineer Grade I, Regd Quality Auditor,
Regd Structural Engineer Grade I,
Chartered Engineer & Regd Bank Panel Valuer,
Collerctorate Panel Engineer, Wealth Tax Valuer
1168-B, Thendral Nagar Main Road, Vengikkal,
Tiruvannamalai - 606 604. Ph 04175-233275
Mob. No : 9443228723, 7708021591

1. Name in block letters : **D. GOVINDAN,**
2. Engineering qualification : **B.E (Civil)., M.E(Struct).,M.Sc(REV)., M.I.E., F.I.V.,**
3. No. of years of Experience : 30 Years experience as a Civil Engineer and Approved Engineer by the Board of Engineers By Govt. of Tamil Nadu and the Collector of Vellore District.

**PLACE : Tiruvannamalai.**
**DATE : 07.04.2025.**

## PROCEEDINGS OF THE VELLORE DISTRICT COLLECTOR
## PRESENT: THIRU S.A.RAMAN, I.A.S.,

Rc.No.A6/5460/2018 Dated: 27.11.2018

Sub: Tamil Nadu Public Building (Licensing) Act 1965 and Rules 1966 – Inclusion of Thiru.D.Govindan in the panel of Private Practicing Engineers under Class-IA in Vellore District – Orders issued.

Ref: (1) Thiru.D.Govindan, No.1168-B, Thendral Nagar, Main Road, Vengikkal, Thiruvannamalai application dated 28.02.2018

(2) This office Lr.R.c.A6/5460/2018 dated:25.10.2018 addressed to the Engineer-in-Chief, Chennai.

(3) Engineer-in Chief, WRD and Chief Engineer (General) PWD, Chepauk, Chennai Lr.No.AEE/T1/AE-2/54601/2018, dated 25.10.2018

<<<<>>>>

Order:

In the reference 1st cited, Thiru.D.Govindan, residing at No.1168-B, Thendral Nagar, Main Road, Vengikkal, Thiruvannamalai. I had submitted requisition to include his name in the panel of Private practicing Engineers under Class IA (One A) list of Vellore District.

2) In the reference 2nd read above, a proposal was sent to the Engineer-in-Chief, Public Works Department (General), Chennai regarding recommending inclusion of the individual's name in the list of panel of Private Engineers under Class IA (One A) category.

3) In the reference 3rd cited, the Engineer-in-Chief, WRD and Chief Engineer (General) PWD, Chepauk, Chennai has stated that the inclusion of the name of Thiru.D.Govindan, residing at No.1168-B, Thendral Nagar, Main Road, Vengikkal, Thiruvannamalai to be included in the panel of Private Practicing Engineers under Class IA (One A) category (Buildings, the cost of which exceeds Rs.50.00 lakhs as per G.O.Ms.No.43, Municipal Administration & Water Supply (MA4) Department, dated 17.2.2011) in Vellore District.

4) As per the recommendations of the Engineer-in Chief, WRD and Chief Engineer (General) PWD, Chepauk, Chennai in his letter third read above, the name of Thiru. Thiru.D.Govindan is ordered to included in the panel of Private Practicing Engineers under Class IA category (Buildings, the cost of which exceeds Rs.50.00 lakhs as per G.O.Ms.No.43, Municipal Administration & Water Supply (MA4) Department, dated 17.2.2011) in Vellore District.

5) All Revenue Divisional Officers and Tahsildars of Vellore District are instructed to accept the public building soundness certificate issued by Thiru.D.Govindan, subject to the conditions.

Sd/- S.A.Raman,
District Collector,
Vellore District.

/By Ordrer/

Personal Assistant to
Collector (G)(i/c),
Vellore.

To

Thiru.D.Govindan,
No.1168-B, Thendral Nagar,
Main Road, Vengikkal,
Thiruvannamalai

Copy to: Sub-Collector, Tirupattur/Vellore/Ranipet.

Copy to: The Engineer-in Chief, WRD and Chief Engineer
(General) PWD, Chepauk, Chennai.